



Madison Cable Corporation

November 1, 1989

John B. Lohmeyer
Chairman X3T9.2
NCR Corporation
3718 N. Rock Road
Wichita, KS 67226

Subject: SCSI-2 Cable Testing Procedures

Enclosed please find impedance test procedures for November mailing.

Sincerely,

Chuck Grant
Quality Engineer

CC: Bob Bellino
Peter Blackford (Astro)
Tom Debiec (Belden)
John Gibson (Berk-Tek)
Mike Patel
Dick Wagner (Montrose)
Willis Xu (C & M)



Madison Cable Corporation

Single Ended Characteristic Impedance Test Method For Round Twisted Pair SCSI Cables

This procedure provides a basic outline for measurement standardization. For measurement details the operational manual of the test equipment should be consulted.

1.0 EQUIPMENT

- 1.1 Single ended time domain reflectometer (TDR) with a 1 nanosecond maximum rise time. Example - Hewlett Packard 54120T
- 1.2 Precision impedance reference line. Example - 50 +/- 1 ohm coaxial cable
- 1.3 Test fixture - appropriate interconnection hardware to connect cable under test to reference line.

2.0 SAMPLE PREPARATION

- 2.1 Sample length - 10 feet.
- 2.2 Strip jacket back 1 1/4 inches maximum.
- 2.3 Pigtail braided shield back to jacket.
- 2.4 Strip conductor insulation back approximately 1/2 inches.
- 2.5 Electrically connect one wire of each pair to the overall shield.

3.0 MEASUREMENT

- 3.1 Connect conductor to be measured to center conductor of test fixture.
- 3.2 Connect shield and one wire of each pair to the shield or ground terminal of the test fixture.
- 3.3 Record the average reflection coefficient. The average shall be measured between 2 and 4 nanoseconds from the test fixture/cable interface.
- 3.4 Calculate the characteristic impedance as follows:

$$Z_c = Z_r \left(\frac{1 + P}{1 - P} \right)$$

Where: Z_c is the measured characteristic impedance.
 Z_r is the average impedance of the reference line.
 P is the average reflection coefficient.



Madison Cable Corporation

Differential Characteristic Impedance Test Method For Round Twisted Pair SCSI Cables

This procedure provides a basic outline for measurement standardization. For measurement details the operational manual of the test equipment should be consulted.

1.0 EQUIPMENT

- 1.1 Time domain reflectometer (TDR) with a 1 nanosecond maximum rise time. Example - Hewlett Packard 54120T
- 1.2 Precision impedance reference line(s). Example - 50 +/- 1 ohm coaxial cable
- 1.3 Test fixture - appropriate interconnection hardware to connect cable under test to reference line.

2.0 SAMPLE PREPARATION

- 2.1 Sample length - 10 feet.
- 2.2 Strip jacket back 1 1/4 inches maximum.
- 2.3 Pigtail braided shield back to jacket.
- 2.4 Strip conductor insulation back approximately 1/2 inches.

3.0 MEASUREMENT

- 3.1 The differential characteristic impedance shall be determined by one of the 4 options that follow.
- 3.2 For each measurement the average reflection coefficient shall be measured between 2 and 4 nanoseconds from the test fixture/cable interface.
- 3.3 Option 1 - Dual step differential TDR
 - 3.3.1 Connect pair to be measured to the test fixture.
 - 3.3.2 Shield and other conductors are allowed to float.
 - 3.3.3 Record average reflection coefficient
 - 3.3.4 Calculate the characteristic impedance as follows:

$$Z_c = Z_r \left(\frac{-1 + P}{1 - P} \right)$$

Where: Z_c is the measured characteristic impedance.
 Z_r is the average impedance of the reference line.
 P is the average reflection coefficient.

3.4 Option 2 - Single step differential TDR

- 3.4.1 The reference line and test fixture are connected to the TDR channel containing the step generator output, plus one other channel.

- 3.4.2 Connect pair to be measured to the test fixture.
- 3.4.3 Tie the overall shield and all other conductors to the scope ground.
- 3.4.4 Display channel 1 - channel 2 on TDR.
- 3.4.5 Record average reflection coefficient.
- 3.4.6 Calculate the characteristic impedance as specified in 3.3.4
- 3.5 Option 3 - Single ended TDR with a balun
 - 3.5.1 The balun is connected between TDR and reference line.
 - 3.5.2 The balun may introduce error to the measurement. A known load, (example - precision resistor matched to reference line) should be measured to verify measurement accuracy.
 - 3.5.3 Connect pair to be measured to the test fixture.
 - 3.5.4 Shield and other conductors are allowed to float.
 - 3.5.5 Record average reflection coefficient.
 - 3.5.6 Calculate the characteristic impedance as specified in 3.3.4
- 3.6 Option 4 - Single ended TDR using 3 terminal measurement technique.
 - 3.6.1 Select a pair to be measured, tie all other wires and the shield together.
 - 3.6.2 The first conductor of the pair, the second conductor of the pair, and the shield with the other conductors will be known as terminals 1, 2, and 3 respectively.
 - 3.6.3 Connect terminal 1 to the center conductor of the test fixture. Connect terminals 2 and 3 to the shield or ground of the test fixture. Record the average reflection coefficient. Call this measurement Pa.
 - 3.6.4 Connect terminal 2 to the center conductor of the test fixture. Connect terminals 1 and 3 to the shield or ground of the test fixture. Record the average reflection coefficient. Call this measurement Pb.
 - 3.6.5 Connect terminals 1 and 2 to the center conductor of the test fixture. Connect terminal 3 to the shield or ground of the test fixture. Record the average reflection coefficient. Call this measurement Pc.
 - 3.6.6 Calculate the characteristic impedance as follows:

$$Z_{char} = Z_r \left(\frac{4 (1 + P_c) (1 - P_a P_b)}{4 (1 + P_c) (1 - P_a) (1 - P_b) - (1 - P_c) (1 - P_a P_b)} \right)$$

$$Z_a = Z_r \left(\frac{1 + P_a}{1 - P_a} \right)$$

$$Z_b = Z_r \left(\frac{1 + P_b}{1 - P_b} \right)$$

$$Z_c = Z_r \left(\frac{1 + P_c}{1 - P_c} \right)$$

$$Z_{char} = \frac{4 Z_c (Z_a + Z_b)}{8 Z_c - (Z_a + Z_b)}$$